

<b>Keyword</b>	instructions	operating instruction
	placing on the market	user
	risk analysis	
<b>Directive refere</b>	Annex I § 3.4	Annex I § 3.3

**Adopted by WGP** 29/06/2000**Adopted by CLAP** 29/06/2000**Subject:** ESR on manufacturing - Safety information given to the user**Question:** What safety information must be given to the user in relation to Annex I points 3.3 and 3.4 ?

**Answer:** When pressure equipment is placed on the market, the manufacturer is required by the PED to ensure that it is accompanied by instructions for the user containing certain safety information ; such information is mandatory. Additional information may be requested by the user or recommended by the manufacturer, and agreed as part of the order or contract ; this information is not a PED requirement and therefore is optional. Both types of information are elaborated below.

The following are required by the PED :

- Details accompanying the CE mark, per clause 3.3a, 3.3b and 3.3c;
- Operating instructions for mounting, putting into service, use and maintenance, per clause 3.4a, which include as far as relevant to the equipment:
  - safe operating limits and design basis (includes anticipated operating and assumed design conditions, intended life, design code used, joint coefficients and corrosion allowances)
  - features of the design relevant to the life of the equipment per clause 2.2.3b last indent
  - residual hazards not prevented by design or protective measures, that might arise from foreseeable misuse, per clause 1.3, 3.3c, and 3.4c
  - technical documents, drawings and diagrams necessary for a full understanding of these instructions, as per clause 3.4b
  - information about replacable parts, for example per clause 2.7

NOTE: Without prejudice of clause 3.4a, other information, not required by the PED, may be included by contractual agreement, such as : hazard analysis, material test certificates, detailed design calculations, "as built" drawings, heat treatment records, welding records, NDT results, results of dimensional check, full records of proof test, details and results of special checks, details of any corrective repair or modifications, full documentation of any concessions made.

Modifications compared to the previous adopted version : Copy of guideline 8/3 (29/06/00) and editorial correction on 2004-09-16.